






PLAN



SECTION A-A



SECTION B-B

SPECIFICATION TABLE		
No.	ITEM	CONTENT
1	CAPACITY	
1.1	PRIMARY SEDIMENTATION CHAMBER	3.557 m ³
1.2	ANAEROBIC FILTRATION CHAMBER	2.235 m ³
1.3	CONTACT AERATION CHAMBER	3.841 m ³
1.4	SECONDARY SEDIMENTATION CHAMBER	1.195 m ³
	TOTAL	10.828 m ³
2	MATERIAL	
2.1	CHAMBER	FRP
2.2	SEPARATION PLATE , BAFFLE	FRP
2.3	FILTER , CONTACT MEDIA	PE , PVC
2.4	DIFFUSER TUBE	PVC
2.5	MANHOLE COVER	ABS
2.6	INFLOW , OUTFLOW PIPE	PVC(100mm.)
3	EQUIPMENT	
3.1	AIR BLOWER	100L/MIN (4UNIT)

* REMARK : STRUCTURE DESIGN SHOULD BE RECOMMEND BY CIVIL ENGINEERS

Rev No.	Revision note	Date	Signature	Checked

CLEAN PRODUCTS CO.,LTD

บริษัท คลีน โปรดักส์ จำกัด

21/277 หมู่ 5 ถนนพหลโยธิน แขวงจันทบุรี เขตบึงกุ่ม กทม. 10230

Tel : (02)363-4107 Fax : (02) 363-4108

DWN	01 / 01 / 07		TITLE	Double Contact Filter Waste Water Treatment Tank
CHECK	P.KAMOL		MODEL	CLEAN - 1100DCF
APPD	P.KAMOL		PROJECT	Standard
SCALE			DRAWING No.	CP 012007044
1 : 50				SHEET No. 1/1