






PLAN



SECTION A-A

SPECIFICATION TABLE		
No.	ITEM	CONTENT
1	CAPACITY	
	1.1 PRIMARY SEDIMENTATION CHAMBER	1.652 m ³
	1.2 CONTACT AERATION CHAMBER	1.028 m ³
	1.3 SECONDARY SEDIMENTATION CHAMBER	0.451 m ³
	TOTAL	3.131 m ³
2	MATERIAL	
	2.1 CHAMBER	FRP
	2.2 SEPARATION PLATE , BAFFLE	FRP
	2.3 CONTACT MEDIA	PE
	2.4 DIFFUSER TUBE	PVC
	2.5 MANHOLE COVER	ABS
	2.6 INFLOW , OUTFLOW PIPE	PVC(100mm.)
3	EQUIPMENT	
	3.1 AIR BLOWER	60L/MIN (1UNIT)



SECTION B-B

* REMARK : STRUCTURE DESIGN SHOULD BE RECOMMEND BY CIVIL ENGINEERS

Rev No.	Revision note	Date	Signature	Checked

CLEAN PRODUCTS CO.,LTD

บริษัท คลีน โปรดักส์ จำกัด

21/277 ตรีเยี่ยมเพลส ถนนนวลจันทร์50 แขวงนวลจันทร์ เขตบึงกุ่ม กทม. 10230

Tel : (02)363-4107 Fax : (02) 363-4108

DWN		01 / 01 / 07		PROJECT	Standard	REV.	
CHECK	P.KAMOL			MODEL	CLEAN - 300SCA		
APPD	P.KAMOL			DRAWING No.	CP 012007049	SHEET No.	1/1



SCALE
1 : 50