






PLAN



SECTION A-A

SPECIFICATION TABLE		
No.	ITEM	CONTENT
1	CAPACITY	
	1.1	PRIMARY SEDIMENTATION CHAMBER 11.430 m ³
	1.2	ANAEROBIC FILTRATION CHAMBER 7.483 m ³
	1.3	CONTACT AERATION CHAMBER 11.445 m ³
	1.4	SECONDARY SEDIMENTATION CHAMBER 5.267 m ³
	TOTAL	35.625 m ³
2	MATERIAL	
	2.1	BODY MATERIAL FRP
	2.2	SEPARATION PLATE , BAFFLE FRP
	2.3	FILTER , CONTACT MEDIA PVC
	2.4	DIFFUSER TUBE PVC
	2.5	MANHOLE COVER ABS , FRP
	2.6	INFLOW , OUTFLOW PIPE PVC(Ø150mm.)
3	EQUIPMENT	
	3.1	AIR BLOWER 32Ax0.75 m ³ /min (AT3000mmaq) 1.5kw , 380/3/50 (1UNIT)
	3.2	CONTROL PANEL OUTDOOR TYPE (1UNIT)



SECTION B-B

* REMARK : STRUCTURE DESIGN SHOULD BE RECOMMEND BY CIVIL ENGINEERS

CLEAN PRODUCTS CO.,LTD

บริษัท คลีน โปรดักส์ จำกัด

21/277 ปรินิคมเฟส ถนนฉนวนจันทร์50 แขวงฉนวนจันทร์ เขตบึงกุ่ม กทม. 10230

Tel : (02)363-4107 Fax : (02) 363-4108

TITLE Double Contact Filter
Waste Water Treatment Tank

MODEL DCF - 40

PROJECT Standard

DRAWING No. CP 012007015

REV.

SHEET No. 1/1

Rev No.	Revision note	Date	Signature	Checked

DWN	01 / 01 / 07	SCALE	1 : 75
CHECK	P.KAMOL		
APPD	P.KAMOL		