






PLAN



SECTION A-A

| SPECIFICATION TABLE |                                 |                                                                              |
|---------------------|---------------------------------|------------------------------------------------------------------------------|
| No.                 | ITEM                            | CONTENT                                                                      |
| 1                   | CAPACITY                        |                                                                              |
| 1.1                 | PRIMARY SEDIMENTATION CHAMBER   | 8.788 m <sup>3</sup>                                                         |
| 1.2                 | ANAEROBIC FILTRATION CHAMBER    | 5.282 m <sup>3</sup>                                                         |
| 1.3                 | CONTACT AERATION CHAMBER1       | 5.282 m <sup>3</sup>                                                         |
| 1.4                 | CONTACT AERATION CHAMBER2       | 5.282 m <sup>3</sup>                                                         |
| 1.5                 | SECONDARY SEDIMENTATION CHAMBER | 4.386 m <sup>3</sup>                                                         |
|                     | TOTAL                           | 29.020 m <sup>3</sup>                                                        |
| 2                   | MATERIAL                        |                                                                              |
| 2.1                 | BODY MATERIAL                   | FRP                                                                          |
| 2.2                 | SEPARATION PLATE , BAFFLE       | FRP                                                                          |
| 2.3                 | FILTER , CONTACT MEDIA          | PVC                                                                          |
| 2.4                 | DIFFUSER TUBE                   | PVC                                                                          |
| 2.5                 | MANHOLE COVER                   | ABS , FRP                                                                    |
| 2.6                 | INFLOW , OUTFLOW PIPE           | PVC(150mm.)                                                                  |
| 3                   | EQUIPMENT                       |                                                                              |
| 3.1                 | AIR BLOWER                      | 32Ax0.60 m <sup>3</sup> /min<br>(AT3000mmaq)<br>0.75kw , 380/3/50<br>(1UNIT) |
| 3.2                 | CONTROL PANEL                   | OUTDOOR TYPE<br>(1UNIT)                                                      |



FOUNDATION REFERS FROM STRUCTURE ENGINEERS

SECTION B-B

\* REMARK : STRUCTURE DESIGN SHOULD BE RECOMMEND BY CIVIL ENGINEERS

| Rev No. | Revision note | Date | Signature | Checked |
|---------|---------------|------|-----------|---------|
|         |               |      |           |         |

## CLEAN PRODUCTS CO.,LTD

บริษัท คลีน โปรดักส์ จำกัด

21/277 ปรินิคมเพลส ถนนพหลโยธิน 50 แขวงพหลโยธิน เขตปทุมธานี กทม. 10230

Tel : (02)363-4107 Fax : (02) 363-4108

|       |              |  |             |                                                  |               |
|-------|--------------|--|-------------|--------------------------------------------------|---------------|
| DWN   | 01 / 01 / 07 |  | TITLE       | Triple Contact Filter Waste Water Treatment Tank |               |
| CHECK | P.KAMOL      |  | MODEL       | TCF - 30                                         |               |
| APPD  | P.KAMOL      |  | PROJECT     | Standard                                         | REV.          |
|       |              |  | DRAWING No. | CP 012007022                                     | SHEET No. 1/1 |